

СОГЛАСОВАНО


Глава администрации пгт. Прогресс

 С.М. Провоторов

« _____ » _____ 2023 г.

УТВЕРЖДАЮ

Главный инженер АО «ДГК»

 В.В. Тениховский

« _____ » _____ 2023 г.

Температурный график качественного регулирования отпуска тепла от Райчихинской
ГРЭС на РЦС при расходе 70 т/час на отопительный сезон 2023-2024 гг.

Тн.в.	8	7	6	5	4	3	2	1	0	-1	-2	-3	-4
T1	49,0	49,0	50,0	51,0	52,0	53,0	54,0	55,0	56,0	57,0	58,0	59,0	61,0
T2	36,0	37,0	38,0	39,0	40,0	40,0	41,0	42,0	43,0	44,0	45,0	46,0	47,0

Тн.в.	-5	-6	-7	-8	-9	-10	-11	-12	-13	-14	-15	-16	-17
T1	62,0	63,0	64,0	65,0	66,0	67,0	68,0	69,0	70,0	71,0	72,0	73,0	74,0
T2	47,0	48,0	49,0	50,0	51,0	52,0	53,0	54,0	54,0	55,0	56,0	57,0	58,0

Тн.в.	-18	-19	-20	-21	-22	-23	-24	-25	-26	-27	-28	-29	-30
T1	75,0	77,0	78,0	79,0	80,0	81,0	82,0	84,0	85,0	86,0	87,0	88,0	89,0
T2	59,0	60,0	61,0	62,0	62,0	63,0	64,0	65,0	66,0	67,0	68,0	69,0	70,0

Тн.в.	-31	-32	-33	-34
T1	91,0	93,0	94,0	95,0
T2	72,0	73,0	74,0	75,0


Главный инженер СП «Амурские тепловые сети»

« _____ » _____ 2023 г.

 С.Н. Громов

Главный инженер СП «Райчихинская ГРЭС»

« _____ » _____ 2023 г.

 В.А. Плотников